

# LOAD DISTURBANCE

## Topics Covered

- Proportional-derivative-integral (PID) compensator.
- Finding closed-loop transfer function.
- Effect of load disturbance.
- Evaluating steady-state angle.

## Prerequisites

- Integration laboratory experiment.
- Filtering laboratory experiment.
- First Principles Modeling laboratory experiment.
- PD Control laboratory experiment.

# 1 Background

The closed-loop position control system of the QUBE-Servo 2 using PID can be represented by the block diagram shown in Figure 1.1. The motor has motor voltage  $V_m$  and torque  $T_d$  as inputs and motor angle  $\theta_m$  as the output. The torque is typically a disturbance torque that you apply manually to the inertial load.  $V_{sd}$  is a simulated external disturbance voltage that is applied through software.




Figure 1.1: QUBE-Servo 2 PID closed-loop position control

## 1.1 DC Motor Model

The QUBE-Servo 2 voltage-to-position transfer function is

$$P(s) = \frac{\Theta_m(s)}{V_m(s)} = \frac{K}{s(\tau s + 1)}, \quad (1.1)$$

where  $K = 21.9 \text{ rad}/(\text{V} \cdot \text{s})$  is the model steady-state gain,  $\tau = 0.15 \text{ s}$  is the model time constant,  $\Theta_m(s) = \mathcal{L}[\theta_m(t)]$  is the motor / disk position, and  $V_m(s) = \mathcal{L}[v_m(t)]$  is the applied motor voltage. If desired, you can conduct an experiment to find more precise model parameters,  $K$  and  $\tau$ , for your particular servo (e.g. performing the Bump Test Modeling or the First Principles Modeling laboratory experiment).

Recall that  $k_m$  is the motor back-emf constant,  $R_m$  is the motor resistance, and  $J_{eq}$  is the equivalent moment of inertia that was found in First Principles Modeling laboratory experiment.

## 1.2 PID Control

The proportional, integral, and derivative control can be expressed mathematically as follows

$$u(t) = k_p e(t) + k_i \int_0^t e(\tau) d\tau + k_d \frac{de(t)}{dt}. \quad (1.2)$$

The control action is a sum of three terms referred to as proportional (P), integral (I) and derivative (D) control gain. The controller Equation 1.2 can also be described by the transfer function

$$C(s) = k_p + \frac{k_i}{s} + k_d s. \quad (1.3)$$

Given the relationship

$$\frac{R_m}{k_m} = \frac{\tau}{K J_{eq}}$$

and assuming the simulated disturbance voltage is zero,  $V_{sd} = 0$ , and no reference,  $r = 0$ , the block diagram can be reduced to Figure 1.2.




Figure 1.2: QUBE-Servo 2 PID disturbance regulation

## 1.3 Final Value Theorem

The Final Value Theorem can be used to determine the steady-state or final value of the system output  $y(t)$  given its Laplace transform  $Y(s)$ . For a system with an unstable pole (i.e. a pole in the right half of the  $s$ -plane), the final value is unbounded. If the system is marginally stable with a complex conjugate pole pair on the imaginary axis, the output of the system will be oscillatory and the final value is not defined. For a stable system response (i.e. all poles of the system are strictly in the left half of the  $s$ -plane), the following holds

$$\lim_{s \rightarrow 0} sY(s) = \lim_{t \rightarrow \infty} y(t). \quad (1.4)$$

## 2 In-Lab Exercises

Based on the model in the QUBE-Servo 2 PD Control laboratory experiment, design a QUARC controller that controls the position of the servo using a PID compensator and can apply a simulated voltage,  $V_{sd}$ , to the motor. See the example given in Figure 2.1 as well as the full block diagram in Figure 1.1.




Figure 2.1: Implements PID position control and adds simulated disturbance

1. Find the closed-loop transfer function from disturbance torque to motor angle

$$G_{\theta,T}(s) = \frac{\Theta_m(s)}{T_d(s)}$$

as a function of the system parameters  $k_p$ ,  $k_i$ ,  $k_d$ ,  $K$ ,  $\tau$ , and  $J_{eq}$ .

2. Find the steady-state angle of the QUBE-Servo 2 when using PD control with gains  $k_p = 2.5$  and  $k_d = 0.01$  and with the full PID with gain  $k_i = 0.1$  for the following load disturbance:

$$T_d = \frac{T_{d0}}{s}. \quad (2.1)$$

Explain how the different terms in the PID control (i.e. proportional, integral, and derivative) effect how a load disturbance is handled.

**Hint:** Use the final value theorem (Equation 1.4) to determine the steady state angle.

3. Assume that a constant simulated disturbance voltage  $V_{sd} = V_{d0} = 1$  V is added to the motor voltage to simulate a disturbance torque  $T_d = T_{d0}$ . Using the model parameters and the equivalent moment of inertia,  $J_{eq}$ , found in First Principles Modeling laboratory experiment determine and evaluate the corresponding disturbance torque amplitude  $T_{d0}$ . Evaluate then the resulting steady-state angle  $\theta_{ss,pd}$  using a proportional gain of  $k_p = 2.5$  V/rad and derivative gain  $k_d = 0.1$ .
4. Connect and power up the QUBE-Servo 2 system and ensure the inertial disc load is mounted.
5. Open the QUARC controller shown in Figure 2.1 to experimentally evaluate the steady-state angle of the QUBE-Servo 2 when a simulated disturbance voltage is applied. Use the QUARC controller to apply a simulated disturbance of  $V_{sd} = 1$  V when using a PD controller with gains  $k_p = 2.5$  and  $k_d = 0.1$ . Attach the position response as well as the motor voltage used.
6. Compare the experimental result with the one found in Question 3. If there were any discrepancies between the theoretical and experimental results, explain what could be the cause.

7. Try varying the proportional gain. What effect does it have on the steady-state angle when a disturbance is added?
8. Re-run the QUARC controller when using a PID controller with the gains  $k_p = 2.5$ ,  $k_d = 0.1$ , and  $k_i = 1.5$ . Attach a response showing the resulting steady-state angle and the motor voltage. Does this match your expected result?
9. How does the integral gain effect the position response when a disturbance is applied?
10. Stop the QUARC controller and turn off the QUBE-Servo 2 if no more experiments will be conducted.

© 2017 Quanser Inc., All rights reserved.

Quanser Inc.  
119 Spy Court  
Markham, Ontario  
L3R 5H6  
Canada  
info@quanser.com  
Phone: 1-905-940-3575  
Fax: 1-905-940-3576

Printed in Markham, Ontario.

For more information on the solutions Quanser Inc. offers, please visit the web site at:  
<http://www.quanser.com>

This document and the software described in it are provided subject to a license agreement. Neither the software nor this document may be used or copied except as specified under the terms of that license agreement. Quanser Inc. grants the following rights: a) The right to reproduce the work, to incorporate the work into one or more collections, and to reproduce the work as incorporated in the collections, b) to create and reproduce adaptations provided reasonable steps are taken to clearly identify the changes that were made to the original work, c) to distribute and publically perform the work including as incorporated in collections, and d) to distribute and publicly perform adaptations. The above rights may be exercised in all media and formats whether now known or hereafter devised. These rights are granted subject to and limited by the following restrictions: a) You may not exercise any of the rights granted to You in above in any manner that is primarily intended for or directed toward commercial advantage or private monetary compensation, and b) You must keep intact all copyright notices for the Work and provide the name Quanser Inc. for attribution. These restrictions may not be waved without express prior written permission of Quanser Inc.